

# Tratament chimic: CONSUM RIDICAT, LIPSA APA CALDA, ZGOMOT CENTRALE MURALE IN CONDENSARE, SCHIMBATOARE IN PLACI



CHIMIA  
INSTALATIEI  
TERMICE

Probleme tratate: **CALCAR, OXIZI, IMPURITATI MECANICE**

Materiale: **INOX / ALUMINIU**

## CHECK SERVICE



Verificare parametrul fluid

## CLEANEX Inox-AI PLUS



Solutie 15-20%  
(cca 1.5kg / 6-7l apa)



Recirculare: 15-25 min



Monitorizare: pH<3

## NEUTRALYZER ALCALIN



Solutie 1-4%  
(cca 100g / 6l apa)



Recirculare: 5-10 min

## APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5  
Incarcare cu apa demineralizata

## INSTAL PROTECT



Dozare 1-2%  
(cca. 1kg / 100l)